


Iss.	
Date	
Modification	
Ckd.	Appd.


BEKA associates
 Hitchin
 England
 company confidential, copyright reserved.

Iss.	1
Date	10.05 2017
Modification	P0176. New drawing.
Ckd.	
Appd.	




VIEW ON ARROW A
 (REAR PANEL DETAILS)

TERMINAL BLOCKS ARE REMOVABLE




TERMINAL CONNECTIONS:



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE FITTED OVER THE 4 STUDS & THE WING NUTS TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MIN.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)
- 4 FINALLY, FIT A SILICONE RUBBER CAP TO THE END OF EACH M3 THREADED ROD.



Title
 CUSTOMER DRAWING for
 BA627E-SS 5 DIGIT SETPOINT STATION
 IN PANEL MOUNTING ENCLOSURE

Drawn	Checked	Scale
SH		NTS
Drawing No.		CD627E-SS