



Iss.	1	Date	01.12 2011	Modification		Appd.	AMH	Ckd.	AMH	Appd.	AC
Iss.		Date		Modification		Appd.		Ckd.		Appd.	


**BEMA associates**  
Hitchin  
England  
company confidential, copyright reserved.



VIEW ON ARROW A  
(REAR PANEL DETAILS)



TERMINAL CONNECTIONS:



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

PANEL CUTOUT:

DIN 43 700:  $92^{+0.8}_{-0} \times 45^{+0.6}_{-0}$

FOR IP66:  $90^{+0.5}_{-0} \times 43.5^{+0.5}_{-0}$

Title      CUSTOMER DRAWING for  
BA327E 5 DIGIT I.S. INDICATOR  
IN PANEL MOUNTING ENCLOSURE

Drawn	RC	Checked	AMH	Scale	NTS
Drawing No.		CD327E			