



Iss.	1	Date	10.05 2017	Modification	P0176. New drawing	Ckd.		Appd.	
Iss.		Date		Modification		Ckd.		Appd.	
BEKA associates Hitchin England company confidential, copyright reserved.									




VIEW ON ARROW A
(REAR PANEL DETAILS)

TERMINAL BLOCKS ARE REMOVABLE



TERMINAL CONNECTIONS:

OPTIONAL BACKLIGHT TERMINALS




SEPARATELY POWERED

LOOP POWERED

COMMON

ROTARY ENCODER TERMINALS




COMMON

B

A

UNIT TERMINALS




4/20mA

TERMINALS 2 & 4 ARE INTERNALLY LINKED FOR JOINING RETURN WIRES

INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE FITTED OVER THE 4 STUDS & THE WING NUTS TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MIN.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)
- 4 FINALLY, FIT A SILICONE RUBBER CAP TO THE END OF EACH M3 THREADED ROD.

BEKA BEZEL



Title
CUSTOMER DRAWING for
BA427E-SS 5 DIGIT I.S. SETPOINT STATION
IN PANEL MOUNTING ENCLOSURE

Drawn SH
Checked
Scale NTS
Drawing No. CD427E-SS