



Iss.	1	Date	23.05 2013	Modification		Ckd.	AMH	Appd.	AC
Iss.		Date		Modification		Ckd.		Appd.	
BEKA associates Hitchin England company confidential, copyright reserved.									




THIRD ANGLE PROJECTION

DIMENSIONS IN mm

DO NOT SCALE




VIEW ON ARROW A
(REAR PANEL DETAILS)




TERMINAL CONNECTIONS:

OPTIONAL
BACKLIGHT
TERMINALS




SEPARATELY
POWERED
LOOP POWERED
COMMON

ROTARY ENCODER
TERMINALS



COMMON
B
A

UNIT
TERMINALS



4/20mA
TERMINALS 2 & 4 ARE
INTERNALLY LINKED FOR
JOINING RETURN WIRES

INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

PANEL CUTOUT:

DIN 43 700: $92^{+0.8}_{-0} \times 45^{+0.6}_{-0}$

FOR IP66: $90^{+0.5}_{-0} \times 43.5^{+0.5}_{-0}$

Title

CUSTOMER DRAWING for
BA427E 5 DIGIT I.S. SETPOINT STATION

Drawn

SH

Checked

AMH

Scale

NTS

Drawing No.

CD427E