

Iss.	Date	Modification	Ckd.	Appd.
1	16.12 2014	First release under project P0170.		
2	10.05 2017	CRN1652, Panel cut-out updated. CRN1617 Rubber cap added.		

  

Iss.	Date	Modification	Ckd.	Appd.
3	15.05 2019	CRN1791. Remove reference to I.S.		

  

<b>BEKA associates</b> Hitchin England company confidential, copyright reserved.				
--	--	--	--	--

THIRD ANGLE PROJECTION

DIMENSIONS IN mm DO NOT SCALE

VIEW ON ARROW A  
(REAR PANEL DETAILS)

TERMINAL CONNECTIONS:

OPTION TERMINALS (WHEN OPTION FITTED):

BACKLIGHT

ALARMS

UNIT TERMINALS

INSTALLATION:

- INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- SCREW CLAMPS ARE FITTED OVER THE 4 STUDS & THE WING NUTS TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MIN.
- FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)
- FINALLY, FIT A SILICONE RUBBER CAP TO THE END OF EACH M3 THREADED ROD.

BEKA BEZEL

PANEL CUTOUT FOR IP66:

Title

CUSTOMER DRAWING for  
BA507E-SS 4 DIGIT INDICATOR  
IN PANEL MOUNTING ENCLOSURE

Drawn KB	Checked .	Scale NTS
-------------	--------------	--------------

Drawing No. CD507E-SS