THIRD ANGLE PROJECTION DIMENSIONS IN mm DO NOT SCALE



VIEW ON ARROW A
(REAR PANEL DETAILS)

TERMINAL BLOCKS ARE REMOVABLE



TERMINAL CONNECTIONS:



OPTION TERMINALS (WHEN OPTION FITTED):



INSTALLATION:

1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.

2 SCREW CLAMPS ARE FITTED OVER THE 4 STUDS & THE WING NUTS TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MIN.

3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

4 FINALLY, FIT A SILICONE RUBBER CAP TO THE END OF EACH M3 THREADED ROD.



Iss.	Date	Modification	Appd.	Ckd.
1	10.05 2017	P0163. New drawing	.	.

BEKA associates Hitchin England

company confidential, copyright reserved.

Title

CUSTOMER DRAWING for BA577E–SS
1 INPUT TIMER
IN RUGGED PANEL MOUNTING ENCLOSURE

Drawn	Checked	Scale
RC	.	NTS

Drawing No. CD577E–SS