



Iss.		Date		Modification		Ckd.		Appd.	
Iss.	1	23.05 2017							


BEKA associates
Hitchin
England
company confidential, copyright reserved.




VIEW ON ARROW A (REAR PANEL DETAILS)



TERMINAL CONNECTIONS:



OPTIONAL TERMINALS (WHEN OPTION FITTED):



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

PANEL CUTOUT:

$$\text{DIN 43 700: } 92^{+0.8}_{-0} \times 45^{+0.6}_{-0}$$

$$\text{FOR IP66: } 90^{+0.5}_{-0} \times 43.5^{+0.5}_{-0}$$

Title

CUSTOMER DRAWING for BA577E
1 INPUT TIMER
IN PANEL MOUNTING ENCLOSURE

Drawn

RC

Checked

.

Scale

NTS

Drawing No.

CD577E