


Iss.		Date	Modification	Ckd.	Appd.
1	23.05 2017				


**BEKA associates**  
Hitchin  
England  
company confidential, copyright reserved.




THIRD ANGLE PROJECTION

DIMENSIONS IN mm


DO NOT SCALE




VIEW ON ARROW A  
(REAR PANEL DETAILS)



TERMINAL CONNECTIONS:



OPTIONAL TERMINALS  
(WHEN OPTION FITTED):



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

PANEL CUTOUT:

DIN 43 700:  $138^{+1.0}_{-0}$  x  $68^{+0.7}_{-0}$

FOR IP66:  $136^{+0.5}_{-0}$  x  $66.2^{+0.5}_{-0}$

Title

CUSTOMER DRAWING for BA588E  
2 INPUT RATE TOTALISER  
IN PANEL MOUNTING ENCLOSURE

Drawn

RC

Checked

.

Scale

NTS

Drawing No.

CD588E