



<div>BEKA associates Hitchin England company confidential, copyright reserved.</div>		Iss.	Date	Modification	Ckd.	Appd.



THIRD ANGLE PROJECTION

DIMENSIONS IN mm


DO NOT SCALE




CERTIFICATION
INFORMATION

VIEW ON ARROW A
(REAR PANEL DETAILS)

SERIAL No.
(& TAG LEGEND IF FITTED)



TERMINAL CONNECTIONS:



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL.
- 3 MAXIMUM RECOMMENDED TIGHTENING TORQUE 22cNm (1.95lbf.in)

PANEL CUTOUT:

DIN 43 700: $138^{+1.0}_{-0}$ x $68^{+0.7}_{-0}$

FOR IP65: $136^{+0.5}_{-0}$ x $66.2^{+0.5}_{-0}$

Title

**CERTIFIED CUSTOMER DRAWING for
BA618CF FIELD BUS INDICATOR
IN PANEL MOUNTING ENCLOSURE**

Drawn

RH

Checked

Scale

NTS

Drawing No.

.

Iss.	Date	Modification	Ckd.	Appd.	<div><div>BEKA</div><div>associates</div><div>Hitchin England</div><div>company confidential, copyright reserved.</div></div>	Iss.	Date	Modification	Ckd.	Appd.
.						

